

Wastewater Supply Requirements

Siting, Construction and Administrative Requirements according to the Reno County Sanitation Code

Siting Requirements

1. System at least 50' from any property line (lagoons 100').
2. System at least 4' above:
 - a) Impervious layer
 - b) Rock formation
 - c) Permanent water table
 - d) Seasonal water table
3. System at least 25' from any public water supply line.
4. System at least 100' from any water well.
5. Greater than 400' from a public sewer line.
6. Complete soil profile of site prior to issuance of permit.

Construction Requirements

1. Construction criteria and plan shall be based on approved soil profile of the site prior to issuance of Permit.
2. A wastewater contractor, licensed by the Health Dept., must perform installation. Note: Applicant should assure the anticipated use of this property conforms to the appropriate Land Use (Zoning) Regulations prior to the construction of a private wastewater system.
3. **AN INSPECTION IS REQUIRED PRIOR TO COVERING ANY PORTION OF THE SYSTEM.** Contact the Health Department for an inspection.
4. Lagoons shall be properly fenced within 15 days of initial use.
5. Inspection ports and manhole risers are required on all systems.

Administrative Requirements

1. Prior to construction, contact the Health Department for a site evaluation and approval to proceed.
2. Pay \$90 permit fee to the Health Dept. (*Fees double if permit not paid prior to installation.*)
3. Requirements for plan approval based upon lot size:
 - 1.0 acre
Public water **and** Enhanced Treatment Wastewater System
 - 1.5 acres
Public **or** private water **and** Enhanced Treatment Wastewater System
 - 3.0 acres
Public **or** private water **and** Conventional **or** Enhanced Treatment Wastewater System.

