

# Wastewater Supply Requirements

Siting, Construction and Administrative Requirements according to the Reno County Sanitation Code

## Siting Requirements

1. System at least 50' from any property line (lagoons 100').
2. System at least 4' above:
  - a) Impervious layer
  - b) Rock formation
  - c) Permanent water table
  - d) Seasonal water table
3. System at least 25' from any public water supply line.
4. System at least 100' from any water well.
5. Greater than 400' from a public sewer line.
6. Complete soil profile of site prior to issuance of permit.

## Construction Requirements

1. Construction criteria and plan shall be based on approved soil profile of the site prior to issuance of Permit.
2. A wastewater contractor, licensed by the Health Dept., must perform installation. Note: Applicant should assure the anticipated use of this property conforms to the appropriate Land Use (Zoning) Regulations prior to the construction of a private wastewater system.
3. **AN INSPECTION IS REQUIRED PRIOR TO COVERING ANY PORTION OF THE SYSTEM.** Contact the Health Department for an inspection.
4. Lagoons shall be properly fenced within 15 days of initial use.
5. Inspection ports and manhole risers are required on all systems.

## Administrative Requirements

1. Prior to construction, contact the Health Department for a site evaluation and approval to proceed.
2. Pay \$275 permit fee to the Health Dept. (*Fees double if permit not paid prior to installation.*)
3. A trip charge of \$50 will be applied on the 3<sup>rd</sup> visit & each visit thereafter.
4. Requirements for plan approval based upon lot size:
  - 1.0 acre with Public water and Enhanced Treatment Wastewater System
  - 1.5 acres with Public or private water and Enhanced Treatment Wastewater System
  - 3.0 acres with Public or private water and Conventional or Enhanced Treatment Wastewater System.

